

**BOSE INSTITUTE**  
Centenary Building,  
P-1/12, CIT Scheme – VII M, Kankurgachi,  
Kolkata – 700 054 (INDIA)

**Minutes of the Pre-bid Conference** held on 19.02.2020 at 3.00 p.m. in the Seminar room of the Department of Biochemistry at centenary building of the Institute regarding Tender Notice No. BI-K/E-TEND/27/2019-20 with tender id : 2020\_BIK\_544317\_1 for procurement of Cold Room

*Members present :*

- Prof. Shubho Chaudhuri
- Prof. Kaushik Biswas
- Dr. Atin Kumar Mandal
- Dr. Smarajit Polley
- Mr. Sougato Banerjee
- Mr. Raju Chandra Paul
- Mr. Sumanta Ghosh

*Bidders present ::*

- M/s Cadillac Filters Pvt Ltd.
- M/s International Commercial Traders
- M/s Blue Star

**Based on the Pre-bid queries raised by the prospective bidders and subsequent resolution adopted by the Institute, the following amendments / corrections may be noted by the prospective bidders for the tender :**

Existing specification	Amended specification
Room size - 8 x 12 x 7 feet (W x L x H)	Room size - 8 x 12 x 7 feet (W x L x H) <b>Internal</b>
Data Logger with necessary software	<b>Deleted</b>
The estimated heat load cannot be less than 15000 BTU. However, the responsibility lies entirely with the bidder to calculate the heat load and submit the same along with technical bid. This is <b>compulsory</b> for the bidder to achieve the given temperature of the cold room in the technical specification.	

**Registrar (Officiating)**